


NOTES:

- Specifications reference the Standard Specifications for Public Work Construction "Green Book" Latest Edition
- Existing asphalt shall be saw-cut or cold milled in a straight, clean manner without chipping or breaking the adjacent pavement. All edges shall be clean and vertical. All cuts shall be parallel or perpendicular to the street centerline, with 90 degree corners whenever practical.
- Asphalt concrete restoration shall be placed after a minimum of 7-days cure time has passed from placement of curb and gutter. Asphalt concrete restoration shall match the existing structural section of asphalt concrete or shall be a minimum of 3-inches thick whichever is greater. Asphalt concrete pavement shall be placed in accordance to Section 306-13.
- Asphalt sections less than 4-inches thick shall be asphalt surface course mix only. Asphalt sections 4-inches thick or greater shall be placed in multiple lifts with a base course asphalt concrete with no lift permitted greater than 4-inches thick. The minimum base course thickness shall be 2.5-inches thick.
- Asphalt concrete materials shall conform to the following:

Asphalt Base Course:	B-PG 64-10 (Per Section 203-6.4)
Asphalt Surface Course:	C2-PG 64-10 (Per Section 203-6.4)
Rubberized Asphalt (where existing or required):	ARHM-GG-C (Per Section 203-11) or 1/2-inch RHMA-G (Per Caltrans Standard Specifications)

Rubberized asphalt shall be placed for surface course layer only and shall not be placed as the entire asphalt concrete pavement section. Type III aggregates are not permitted for any surface course.
- Additional placement of slurry seal or chip seals shall be applied as required by the City for recently resurfaced streets. Asphalt restorations which do not meet these requirements are subject to removal and replacement.

REVISION	APPROVED	DATE	CITY OF SANTEE STANDARD DRAWING	APPROVED:  PRINCIPAL CIVIL ENGINEER R.C.E. 60112 DATE: 5/10/2018
ORIGINAL	C. SCHMITZ	3/20/2018		
RUBBERIZED ASPHALT	S. MILLER	8/30/2018	SLOT TRENCH RESURFACING	DRAWING NUMBER PW - 03